

**TESTING SERVICES, INC.**

817 SHOWALTER AVE., PO BOX 2041
 DALTON, GA 30722-2041
 PHONE: (706)226-1400 FAX: (706)226-6118

TEST REPORT

CLIENT:	Shaw Contract	REPORT NUMBER:	61821BR
	PO Drawer 2128	LAB TEST NUMBER:	2645-0983
	Dalton, GA 30722-2128	DATE:	September 15, 2014
		PAGE:	1 of 1

Test Material:

Style	5T108 Duotone 18X36
Test #	R-140826-08708

Test Scope:

Testing Services Inc was instructed by the client to assess static generating propensity of submitted floor covering material. The test material is brought to equilibrium at controlled atmospheric conditions and is walked on by a test operator in a specified manner with specified shoe soles and heels. The static charge, which builds up on the operator, is monitored continuously by a voltage indicator or recorder. The results of this test relate to the sample tested. Its static performance may be altered in service as a result of wear, soiling, cleaning, temperature, relative humidity, etc.

Test Method:

AATCC Method 134: Electrostatic Propensity of Carpets

Test Equipment:

Base: Earthed Metal Base Plate 2000 mm x 1000 mm
 Underlayment: Plate: Earth grounded metal pipe
 Sandals: Neolite in accordance with Annex A
 Reference Carpets: AATCC Protected/Un Protected
 Voltage Measuring: Input Resistor(Leasametric) and Hand Electrode
 Voltage Recording: Continuous Chart (Esterline Angus)
 Chamber Measuring: Wall Chart (Dickson)/ Hand Held (Dickson)
 Chamber Conditions: 70°F ±1° 20% RH ± 3%

Test Results:

A 27" X 36" specimen was cut from the sample lot and tested as received after conditioning.

Day	Mode	Reading	Polarity
1	Step	1.00 ky	Negative
2	Step	1.00 kv	Negative
Average	Step	1.00 kv	Negative

Day	Mode	Reading	Polarity
1	Scuff	2.00 kv	Negative
2	Scuff	2.00 kv	Negative
Average	Scuff	2.00 kv	Negative

Approved By:

Erle Miles, Jr V.P., Testing Services Inc

TSI Accreditation:

Our laboratory is accredited with US Dept of Commerce, National Institute of Standards and Technology: ISO/IEC 17025:2005. Our code # is NVLAP 100108-0. However, it should be noted that some or all of the tests performed are not under our scope of accreditation due to the work not fully conforming to the standard, or it being outside the scope of our accreditation, or subcontracted. The above testing was under our scope of accreditation.

Uncertainty:

We undertake all assignments for our clients on a best effort basis. Our findings and judgments are based on the information to us using the latest test methods available.

OUR LETTERS AND REPORTS APPLY ONLY TO THE SAMPLE TESTED AND ARE NOT NECESSARILY INDICATIVE OF THE QUALITIES OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS. THESE LETTERS AND REPORTS ARE FOR THE USE ONLY OF THE CLIENT TO WHOM THEY ARE ADDRESSED AND THEIR COMMUNICATION TO ANY OTHERS OR THE USE OF THE NAME TESTING SERVICES, INC. MUST RECEIVE OUR PRIOR WRITTEN APPROVAL. THE REPORTS AND LETTERS, AND OUR NAME, OUR SEALS, OR OUR INSIGNIA ARE NOT UNDER ANY CIRCUMSTANCES TO BE USED IN ADVERTISING TO THE GENERAL PUBLIC.